


**ELECTRICAL HVAC PLAN-GYM**  
 SCALE: 1/8"=1'-0"  
 NORTH

**KEY NOTES:**

1. NEMA "3R", 200/3 FUSED DISC. WITH 150A FRN FUSES. ELECTRICAL CONTRACTOR TO MAINTAIN ALL REQUIRED CLEARANCES.
2. NEMA "3R", 30/3 FUSED DISC. WITH 25A FRN FUSES. ELECTRICAL CONTRACTOR TO MAINTAIN ALL REQUIRED CLEARANCES.
3. TEMP SENSOR T-STAT. MECHANICAL TO FURNISH AND INSTALL 1/2°C. TO ACCESSIBLE CEILING SPACE FOR CORRESPONDING MECHANICAL UNIT. COORDINATE EXACT LOCATION WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.
4. INTERLOCK FAN WITH THERMOSTAT. PROVIDE ADDITIONAL RELAYS AS REQUIRED. SEE MECHANICAL FOR ADDITIONAL INFORMATION.
5. PROVIDE INTERCONNECT LOW VOLTAGE WIRING PER MANUFACTURER'S REQUIREMENTS. SEE MECHANICAL FOR MORE INFORMATION.
6. 120V CIRCUIT TO NEAREST SOURCE.
7. NEMA "3R", 30/3 FUSED DISC. WITH 30A FRN FUSES. ELECTRICAL CONTRACTOR TO MAINTAIN ALL REQUIRED CLEARANCES.

TRW Architecture Planning  
 515 EAST PARKWAY CT.  
 Boise, Idaho 83706  
 208.371.9298  
 trw@trwarchitecture.com  
 www.trwarchitecture.com



ADAMS COUNTY COMMUNITY CENTER  
 MICHIGAN STREET  
 COUNCIL, IDAHO

99U05	
Date:	8/8/2018
Drawn By:	JRR
Checked By:	STJ
Revisions	
▲	
▲	
▲	
▲	

**eci**  
 Engineering Consultants Incorporated  
 303 Federal Way Boise, Idaho 83705  
 Phone (208) 376-9820 Fax (208) 376-9822  
 www.eciboise.com

**E2.2**  
 ELECTRICAL HVAC  
 PLAN-GYM